






Product family features

- Universal Input 100~240Vac/127-370Vdc
- 100% Full Load Burn-in Test
- Cooling by Free Air Convection
- All Round Protections: SCP/OLP/OVP/OTP
- LED Indicator for DC Power On
- LED Indicator for DC Low
- 3 Years Warranty

Naming rules



Model List


Product Modle	Input voltage	Output power	Output voltage	Output current	Ripple	Efficiency
PIS120-12	90-264Vac 127-370Vdc	120W	12V	10A	100mv	86%
PIS120-24		120W	24V	5A	120mv	88%
PIS120-48		120W	48V	2.5A	150mv	89%


Electrical Specifications


	Parameter	Not	es / Conditions				
	Line regulation	±1%					
Output	Load regulation	±2%					
	Voltage accuracy	±1%					
	Turn-on time	<2500ms(115VAC Full	<2500ms(115VAC Full load),<1200ms(230VAC Full load)				
	Hold-up time	>10ms (115VAC Full lo	>10ms (115VAC Full load), >16ms (230VAC Full load)				
	Rise time	<200ms (115VAC Full I	<200ms (115VAC Full load), <200ms (230VAC Full load)				
Input	Input voltage range	90-264VAC [127 ~ 370V	90-264VAC [127 ~ 370VDC]				
	Input current	<3A (115V AC & Full lo	<3A (115V AC & Full load) ;<1.5A (230V AC & Full load)				
	Input frequency	0/50-60Hz	0/50-60Hz				
	On/off times	> 10,000 times	> 10,000 times				
	Inrush current	<40A (115VAC Full loa	<40A (115VAC Full load) , <70A (230VAC Full load)				
	Standby loss	<1W (115/230VAC N	<1W (115/230VAC No load)				
	Short protection	Shut off output voltage turned on again	Shut off output voltage, the power supply will recover after the power is turned on again				
	Over load protection	Rated output power:1	Rated output power:105%~ 160%; Peak Load function				
	over load protection	• •	Protection type: Constant current limiting, recovers automatically after fault condition is removed				
		PIS120-12	PIS120-24	PIS120-48			
		PIS120-12 15-17V	PIS120-24 28-34V	PIS120-48 60-66V			
& Safety	Over output voltage protec	15-17V tion Enter the overvoltage p power supply is less tha	28-34V rotection state, the input power in its no-load power, there is no o e eliminated, and the AC voltage	60-66V consumption of the output voltage, the			
Protection & Safety	Over output voltage protection	15-17V Enter the overvoltage p power supply is less that fault source needs to be to resume normal oper (1) When the ambient protection value, the p will be cut off in order	28-34V rotection state, the input power in its no-load power, there is no o e eliminated, and the AC voltage	consumption of the output voltage, the should be restarted r temperature output voltage			
Protection & Safety		15-17V Enter the overvoltage p power supply is less that fault source needs to be to resume normal oper (1) When the ambient protection value, the p will be cut off in order	rotection state, the input power in its no-load power, there is no de eliminated, and the AC voltage ation. temperature exceeds above overotection will bestarted and the to protect the power supply; (2) ower is turned on again	consumption of the output voltage, the should be restarted r temperature output voltage			
Protection & Safety	Over temp protection	tion Enter the overvoltage p power supply is less that fault source needs to be to resume normal oper (1) When the ambient protection value, the p will be cut off in order will recover after the p	rotection state, the input power in its no-load power, there is no de eliminated, and the AC voltage ation. temperature exceeds above overotection will bestarted and the to protect the power supply; (2) ower is turned on again	consumption of the output voltage, the should be restarted r temperature output voltage			
Protection & Safety	Over temp protection Hi-pot	15-17V Enter the overvoltage power supply is less that fault source needs to be to resume normal oper (1) When the ambient protection value, the pwill be cut off in order will recover after the power should be some some supplementation.	rotection state, the input power in its no-load power, there is no de eliminated, and the AC voltage ation. temperature exceeds above overotection will bestarted and the to protect the power supply; (2) ower is turned on again	consumption of the output voltage, the should be restarted r temperature output voltage			


Parameter	Notes / Conditions	
Surrounding air temperature	Ta= -20-70°C Pls refer the derating curve	
Operating Humidity	20-95% RH, non-condensing	
Storage Temp./Humidity	-40-+85°C, 10-95% RH, non-condensing	
Temp-coefficient	±0.03%/°C (0 ~ 50°C)	
Vibration Resistant	10 ~ 500Hz, 2G 10minutes/cycle, X、Y、Z axis/60 minutes Installation: meet IEC60068-2-6	
Certified	CE, EAC, UL508, UKCA, TUV, RCM+SAA,	
Safety	IEC 62368-1:2018; TP TC 004/2011; EN 55035:2017+A11:2020; BS EN 55035:2017+A11:2020;AS/NZS 62368.1:2022	
ЕМС	TP TC 002/2011; EN55032:2015+A11:2020; EN IEC 61000-3-3:2019+A2:2021; EN61000-3-3:2013+A2:2021; EN 55035:2017+A11:2020; BS EN 55032:2015+A11:2020; BS EN IEC61000-3-2:2019+A1:2021; BS EN 61000-3-3:2013+A2:2021; BS EN 55035:2017+A11:2020	
MTBF	50,000H,MIL-HDBK-217F(25°C)	
Dimension	36 x 95.3 x 108.0mm	
Packaging	450g 22pcs/9.9kg/0.7cuft/carton 425*320*200mm (L*W*H)	
DC-OK led	LED(Green) DC OK LED light will be ON when the power supply is properly operated	
DC-Low led	LED(Red): 1. the output voltage are lower than rating voltage*80%(±5%).	
All specifications valid at nominal voltage 230VAC, Rated full load and +25°C after warm-up time, unless otherwise stated. 2. Ripple & noise are measured at 20MHz of bandwidth by using a 12" twisted pair-wire terminated with a 0.1uf & 47uf parallel capacitor 3. Accuracy: include the setting tolerance, line regulation and load regulation. 4. Power supply that is as a part of system, must be test before install in the end of system. 5. Installation clearances: 25mm on top, 25mm on the bottom, 25mm on the left and right side are recommended when loaded permanently with full power. In case the adjacent device is a heat source. 25mm clearance is recommended. 6. Derating may be needed under low input voltage. Please check the derating curve for more details. 7.The ambient temperature derating of 3.5°C/1000m with fan-less models and of 5°C /1000m with fan models for operating altitude higher than 2000m(6500ft).		
	Surrounding air temperature Operating Humidity Storage Temp./Humidity Temp-coefficient Vibration Resistant Certified Safety EMC MTBF Dimension Packaging DC-OK led DC-Low led All specifications valid at nor otherwise stated. 2. Ripple & noise are measure a 0.1uf & 47uf parallel capace 3. Accuracy: include the set 4. Power supply that is as a p 5. Installation clearances: 25 recommended when loaded with full power. In case the a 25mm clearance is recommended with full power. In case the a 25mm clearance is recommended of 7. The ambient temperature models for operating altitude.	

Derating curve chart











No	Marking	Assignment	
1			
2		- DC OK	
3	DC(+)	DC(+)Ou5tput terminal	
4	DC(-)	DC(-)Ou5tput terminal	
5	AC(L)	AC(L)input terminal	
6	AC(N)	AC(N)input terminal	
7		NC	
/	V-ADJ	DC Output voltage adjustment trimme	
/	DC OK	DC Output OK indication LED(Green)	
/	DC LOW	DC Output Low indication LED(Red)	

Reduction Curve Chart


Temperature reduction curve






Note:Input Derating not evaluated by UL


Block diagram



Application note

A. Series operation







Note:

- 1. Series operation can be connected as shown in above;
- 2. Load current should be less than the current value of the product with the lowest output current specified at the product specification with the power supply at series connection.

B. Series operation



Parallel Operation A (Unable to use)




Parallel Operation B (Backup)

Note:


- 1. Parallel operation should be composed with the same products, while the connection should be as shown as "Parallel operation B";
- 2. In parallel operation B, current capacity cannot be increased, while it should be used for backup only. Moreover, diode that is to be added during parallel operation should be selected after considering its voltage drop, output voltage and current capacity.

C. Mounting spacing



Mounting method should be considered with airflow. Leave enough space between the units when several units are mounted together. Forced air cooling makes protection against heat better.

How to fix



Remove the power supply to D direction, pulling C part by using tools, such as a screwdriver, to downward direction.

d. Cautions

- (1) Please confirm if the capacity of the product is suitable for your intended application before putting it in use;
- (2) Only the rated input voltage specified on the product should be used;
- (3) Only the wires with rated capacity should be connected to this product, as allowable voltage and current is varied according to each type of wire;
- (4) Ground terminal of the power supply must be grounded before use to prevent electric shock or electro-magnetic interference;
- (5) Be cautions to keep the product clean as foreign matter near the input & output terminal or inside if the product could cause series damages;
- (6) If a fuse installed in the product blows off, the product should experience damages not only to the fuse but also to other parts as well. Therefore, the product is to be required for maintenance work from customer service department as well as replacement of the fuse;
- (7) Due to constant leakage current flows within the product, extra caution should be made if multiple number of products are used connecting to each other as total leakage current could be amounted beyond the capacity;
- (8) Be sure to avoid any physical contact with the product since some of the parts inside of the product are beingfunctioned at high voltage, which could cause serious electric shock;
- (9) For the purpose of safety as well as reliability of the product, please avoid using the product at the followingsites: A place near water or fire A place with high room temperature and poor ventilation A place with a presence of foreign subject or dust A place near volatile or flammable compounds A place with high humidity- A place vulnerable for vibration or shock;
- (10) Do not inspect or repair the product while the power is applied;
- (11) Unauthorized modification should be avoided in order to prevent series injury or physical loss due to any malfunction;
- (12) In case of power outage while in operation, be sure to turn off the power supply.

e. Warranty

- (1) Repair service will be provided for free upon any mechanical, technical or functional defects during theguaranteed warranty, however, any defects or malfunction due to international infliction or negligence by customers will be repaired at the customer's expense;
- (2) Guaranteed warranty of the product runs for 3 years, while appearance and specification of the product is subject for change without any prior notification for the purpose of quality improvement of the product.

Tag information













NOTE: FOR USE IN A CONTROLLED ENVIRONMENT.REFER TO MANUAL FOR ENVIRONMENTAL CONDITIONS. REMARQUE :POUR UNE UTILISATION DANS UN ENVIRONNEMENT CONTRÔLÉSE RÉFÉRER AU MANUEL POUR LES CONDITIONS ENVIRONNEMENTALES.

Packaging(Agreed by both parties for packaging requirement)



Carton L*W*H(mm)	Pcs/Carton	Net weight/Pcs(g)	Net weight/Carton(kg)	Gross weight/Carton(kg)
425*320*200	24	750	9.9	12